



SIDE VIEW

END VIEW

TANK: CATEGORY 3. 4" 4500 GALLON 2 COMPARTMENT TANK REINFORCED WITH FIBER AND #4 STEEL 12" O/C BOTH WAYS. 4" WALLS AND 4" BOTTOM. INLET AND OUTLET RESILIENT CONNECTORS PER ASTM-923-98. CONNECTORS MUST BE USED WITH APPROVED CLAMP. CONNECTOR WILL ACCEPT 4" PVC PIPE.

LIDS: 5" LID WITH 1-22" ROUND MANHOLE COVER AT EACH END OF TANK
 8" LID WITH 1-22" ROUND MANHOLE COVER AT EACH END OF TANK
 LID IS REINFORCED WITH GRADE 60 REBAR.

TANK & LIDS: 4000 PSI CONCRETE AT 28 DAYS

IMPRINTED ON INLET END OF TANK:

LEGEND: FSI 4500 STATE APPROVAL NUMBER: 01-011-BM5-C3

WEIGHTS: TANK ONLY 22,110
 TANK & 5" LID 29,500
 TANK & 8" LID 33,930

THIS TANK HOUSES THE 3.0 BIOMICROBICS FAST UNIT.

THIS SEWAGE TREATMENT RECEPTACLE HAS BEEN DESIGNED, CONSTRUCTED AND STRUCTURALLY TESTED IN ACCORDANCE WITH CHAPTER 64E-6.013, FLORIDA ADMINISTRATIVE CODE, (FAC) DATED APRIL 28, 2011.

DRAWING NOT TO SCALE

HOUSES BIOMICROBICS
 3.0 FAST

FLORIDA SEPTIC, INC

P.O. BOX 545
 HAWTHORNE, FLORIDA 32640
 (800) 940-8265

MODEL:

4" 4500 GALLON TANK

REVISED:
 05/01/2011

APPROVAL DATE:
 OCTOBER 31, 2003