



SIDE VIEW

END VIEW

TANK: CATEGORY 4. 8" 1250 GALLON 2 COMPARTMENT TANK REINFORCED WITH GRADE 60 #4 REBAR 6" O/C. BOTH WAYS. 8" WALLS AND 8" BOTTOM. INLET AND OUTLET RESILIENT CONNECTORS PER ASTM-923-98. CONNECTORS MUST BE USED WITH APPROVED CLAMP. CONNECTOR WILL ACCEPT 4" PVC PIPE.

LIDS: 8" LID WITH 1-24" ROUND MANHOLE COVER AT EACH END OF TANK
LID IS REINFORCED WITH GRADE 60 REBAR.

TANK & LIDS: 4000 PSI CONCRETE AT 28 DAYS

IMPRINTED ON INLET END OF TANK:
LEGEND: FSI 1250

WEIGHTS: TANK ONLY 21,175
TANK W/ 8" LID 28,045

THIS TANK IS RATED FOR H-20 LOADING WHEN USED WITH 8" TRAFFIC LID AND TANK BURIAL DEPTH IS AT LEAST 18" BELOW GROUND SURFACE.

THIS TANK COMPLIES WITH SECTION 1003.5.1 OF THE 2001 FLORIDA PLUMBING CODE

INTERCEPTOR CAPACITY PER SECTION 1003.5.1 IS SITE SPECIFIC.

DRAWING NOT TO SCALE

FLORIDA SEPTIC, INC
P.O. BOX 545
HAWTHORNE, FLORIDA 32640
(800) 940-8265

MODEL:

8" 1250 GAL. TANK