



TANK: 8" SAMPLING BOX REINFORCED WITH #4 STEEL 6" O/C, BOTH WAYS, 8" WALLS AND 8" BOTTOM. INLET AND OUTLET RESILIENT CONNECTORS PER ASTM-923-98. CONNECTORS MUST BE USED WITH APPROVED CLAMP, CONNECTOR WILL ACCEPT 8" PVC PIPE.

LIDS: 8" LID WITH 1-8" COUPLING CENTERED ON LID OF TANK
LID IS REINFORCED WITH GRADE 60 REBAR.

TANK & LIDS: 4000 PSI CONCRETE AT 28 DAYS

WEIGHTS: TANK ONLY
TANK W/ 8" LID

DRAWING NOT TO SCALE

FLORIDA SEPTIC, INC
P.O. BOX 545
HAWTHORNE, FLORIDA 32640
(800) 940-8265

MODEL:
8" WALL SAMPLING BOX