



**SIDE VIEW**

**END VIEW**

**TANK: CATEGORY 3.** 3" 1500 GALLON 1 COMPARTMENT TANK REINFORCED WITH FIBRILLATED POLYPROPYLENE FIBER. 3" WALLS AND 3" BOTTOM. INLET AND OUTLET RESILIENT CONNECTORS PER ASTM-923-98. CONNECTORS MUST BE USED WITH APPROVED CLAMP. CONNECTOR WILL ACCEPT 4" PVC PIPE.

**LIDS:** 4" LID WITH 1-22" ROUND MANHOLE COVER AT EACH END OF TANK  
 8" LID WITH 1-22" ROUND MANHOLE COVER AT EACH END OF TANK  
 LID IS REINFORCED WITH GRADE 60 REBAR.

**TANK & LIDS:** 4000 PSI CONCRETE AT 28 DAYS

IMPRINTED ON INLET END OF TANK:

**LEGEND: FSI 1500 STATE APPROVAL NUMBER: 01-011-20P-C3**

**WEIGHTS:** TANK ONLY 8,100  
 TANK & 4" LID 10,650  
 TANK & 8" LID 13,200

THIS SEWAGE TREATMENT RECEPTACLE HAS BEEN DESIGNED, CONSTRUCTED AND STRUCTURALLY TESTED IN ACCORDANCE WITH CHAPTER 64E-6.013, FLORIDA ADMINISTRATIVE CODE, (FAC) DATED APRIL 28, 2010.

DRAWING NOT TO SCALE

**FLORIDA SEPTIC, INC**

**P.O. BOX 545  
 HAWTHORNE, FLORIDA 32640  
 (800) 940-8265**

**MODEL:**

**3" 1500 GAL TANK**

**REVISED:**

**05/01/11**

**APPROVAL DATE:**

**05/31/01**