



TANK: CATEGORY 4. 4" 300 GALLON 1 COMPARTMENT TANK REINFORCED WITH FIBRILLATED POLYPROPYLENE FIBER. 4" WALLS AND 4" BOTTOM. INLET AND OUTLET RESILIENT COMMECTORS PER ASTM-923-98. CONNECTORS MUST BE USED WITH APPROVED CLAMP. CONNECTOR WILL ACCEPT 4" PVC.

LIDS: 3" LID WITH 1-22" ROUND MANHOLE COVER.
 8" LID WITH 1-22" ROUND MANHOLE COVER.
 LID IS REINFORCED WITH GRADE 60 REBAR.

TANK & LIDS: 4000 PSI CONCRETE AT 28 DAYS

IMPRINTED ON INLET END OF TANK:

LEGEND: FSI 300

STATE APPROVAL NUMBER: 01-011-93S-C4

WEIGHTS: TANK ONLY 3,756
 TANK W/ 3" LID 4,346
 TANK W/ 8" LID 5,956

THIS SEWAGE TREATMENT RECEPTACLE HAS BEEN DESIGNED, CONSTRUCTED AND STRUCTURALLY TESTED IN ACCORDANCE WITH CHAPTER 64E-6.013, FLORIDA ADMINISTRATIVE CODE, (FAC) DATED AUGUST 1, 2000.

THIS TANK IS RATED FOR H-20 LOADING WHEN USED WITH 8" TRAFFIC LID AND TANK BURIAL DEPTH IS AT LEAST 18" BELOW GROUND SURFACE.

THIS TANK COMPLIES WITH SECTION 1003.5 OF THE 2001 FLORIDA PLUMBING CODE.

INTERCEPTOR CAPACITY PER 1003.5.1 IS SITE SPECIFIC.

DRAWING NOT TO SCALE

FLORIDA SEPTIC, INC

P.O. BOX 545
 HAWTHORNE, FLORIDA 32640
 (800) 940-8265

MODEL:

4" 300 GAL. TANK

REVISED:

05/01/2011

APPROVAL DATE:

08/01/00